



Australian Standard

STANDARDSMARK SCHEDULE

Fylost Roto Plastics Pty Ltd

ABN 93 010 816 949

2 Stradbroke Street, Heathwood, QLD 4110, AUSTRALIA

AS/NZS 4766(Int): 2002 - Polyethylene storage tanks for water and chemicals

Model identification of the goods on which the STANDARDSMARK may be used:

| Capacity L | Diameter mm | Height to overflow mm | Wall profile | Lower wall thickness | Upper Wall Thickness | Bottom knuckle radius mm | Application | Max. Service temp. °C | Specific gravity | Outlet Fittings mm |
|------------|-------------|-----------------------|--------------|----------------------|----------------------|--------------------------|-------------|-----------------------|------------------|--------------------|
| 1000 | 880 | 1680 | Corrugated | 4.5 | 4.5 | 25 | water | 23 | 1 | 0-50 |
| 1200 | 1200 | 1260 | Corrugated | 4.5 | 4.5 | 25 | water | 23 | 1 | 0-50 |
| 2300 | 1400 | 1520 | Corrugated | 4.5 | 4.5 | 25 | water | 23 | 1 | 0-50 |
| 3000 | 1380 | 2100 | Corrugated | 4.5 | 4.5 | 25 | water | 23 | 1 | 0-50 |
| 5000 | 2015 | 1630 | Corrugated | 6 | 4.5 | 38 | water | 23 | 1 | 0-50 |
| 7000 | 2570 | 1440 | Corrugated | 6 | 6 | 38 | water | 23 | 1 | 0-50 |
| 11500 | 2570 | 2230 | Corrugated | 8 | 6 | 38 | water | 23 | 1 | 0-50 |
| 22500 | 3650 | 2210 | Corrugated | 12 | 8 | 38 | water | 23 | 1 | 0-50 |

Rotationally moulded polyethylene storage tanks. Branded as 'Oz Poly'.

End of Record

Alex Ezrakhovich - General Manager Certification
For and on behalf of SAI Global

Authorised Local Signatory, SAI Global

Licence No.: SMKP20375



Issue Date: 07 November 2006



MEMBER